





FIRE HYDRANT COLORS

USE NFPA 291: RECOMMENDED PRACTICE FOR FIRE FLOW TESTING AND MARKING OF HYDRANTS TO DETERMINE FLOWS AND PRESSURES.

	Color	Gallons per minute
	Blue	1,500
	Green	1,000
	Orange	500-999
	Red	Below 500